

Article type	Number of circuits	On / Off control	TPI control	Modulating heater	Room temperature control	Outside temperature control	Controller class	Efficiency gain	
RAA11		x			1		I	1.0%	
RAA21		x			1		I	1.0%	
RAA31..		x			1		I	1.0%	
RAA41		x			1		I	1.0%	
REV-13..		x	x		1		IV	2.0%	
REV-17..		x	x		1		IV	2.0%	
REV-24..		x	x		1		IV	2.0%	
RAV11..		x	x		1		IV	2.0%	
RDF800KN	1	x			1		I	1.0%	
RDG110	1	x			1		I	1.0%	
RDG100		x	x		1		IV	2.0%	
RDG100T		x	x		1		IV	2.0%	
RDG100T/H		x	x		1		IV	2.0%	
RDG100KN		x	x		1		IV	2.0%	
RDG160T		x		x	1		V	3.0%	
RDG160KN		x		x	1		V	3.0%	
RDG165KN		x		x	1		V	3.0%	
RDG400		x		x	1		V	3.0%	
RCU10		x	x		1		IV	2.0%	
RCU15		x	x		1		IV	2.0%	
QAX903-9	up to 12	(x)	(x)	(x)	12	1	VIII	5.0%	
QAX913-9	up to 12	(x)	(x)	(x)	12	1	VIII	5.0%	
(x) in combination with separate heater controller (e.g. Synco 700)									
RLA162	2			x	1	1	VI	4.0%	
RVS13	up to 2	x			1	1	VII	3.5%	
					1		I	1.0%	
						1	III	1.5%	
RVS43	< 3			x	1	1	VI	4.0%	
					1		V	3.0%	
						1	II	2.0%	
	x					1	1	VII	3.5%
						1		I	1.0%
							1	III	1.5%
≥ 3 *				x	1	1	VIII	5.0%	
					1		VIII	5.0%	
RVS63	< 3			x	1	1	VI	4.0%	
					1		V	3.0%	
						1	II	2.0%	
	x					1	1	VII	3.5%
						1		I	1.0%
							1	III	1.5%
≥ 3 *				x	1	1	VIII	5.0%	
					1		VIII	5.0%	
RVS21	< 3			x	1	1	VI	4.0%	
					1		V	3.0%	
						1	II	2.0%	
	x					1	1	VII	3.5%
						1		I	1.0%
							1	III	1.5%
≥ 3 *				x	1	1	VIII	5.0%	
					1		VIII	5.0%	

* with "own" zones or additional zone controllers (RVS46)

** additional zone controllers (OCI365, RVS46)

*** additional zone controllers (RVS46)

**** 3 pre-controller, 4 heating circuits, 2 DHW circuits