

## EU type examination certificate

## EU-Baumusterprüfbescheinigung

CE-0085DL0336

Product Identification No.  
Produkt-Identnummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	BAXI S.p.A. Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)
<b>Distributor</b> <i>Vertreiber</i>	BAXI S.p.A. Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)
<b>Product Category</b> <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
<b>Product Description</b> <i>Produktbezeichnung</i>	Condensing combi water heater optional also as water heater
<b>Model</b> <i>Modell</i>	LUNA STYLE...; LUNA PLATINUM...
<b>Countries of Destination</b> <i>Bestimmungsländer</i>	AL, AT, BE, BG, CH, CY, CZ, DE, EE, ES, FI, FR, GB, GR, HR, HU, IE, IT, LT, LU, LV, MK, NL, NO, PL, PT, RO, SE, SI, SK, TR
<b>Test Reports</b> <i>Prüfberichte</i>	supplement test: 21-00813-AB02-033 from 30.09.2021 (EBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	EU/2016/426 A III G (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017) DVGW CERT ZP 3100 (07.10.2020)
<b>Date of Expiry / File No.</b> <i>Ablaufdatum / AZ</i>	24.07.2030 / 21-0644-GER

70208-04-DE

11.11.2021 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der ZertifizierungsstelleDeutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01DVGW CERT GmbH  
ZertifizierungsstelleJosef-Wirmer-Str. 1-3  
53123 BonnTel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993www.dvgw-cert.com  
info@dvgw-cert.com

**Elektrical Data** 230 V AC, 50 Hz, IPX5D  
**Elektrische Daten**

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2N	20/25 mbar	BE	
I3B/P	30 mbar	CY	
I3B/P	37 mbar	BE	
II2E3B/P	20, 30 mbar	LU	
II2ELw3B/P	20, 30 mbar	PL	only for types ...1.35, ...30 and ...35
II2ELwLs3B/P	20,20,13, 37 mbar	PL	only for types ...1.12, ...1.24 and 24
II2Er3P	20/25, 37 mbar	FR	
II2H3B/P	20, 30 mbar	CH, CZ, EE, FI, GB, GR, HR, IE, IT, LT, LV, NO, RO, SE, SK, TR	
II2H3B/P	20, 50 mbar	AT	
II2H3P	20, 37 mbar	CH, CZ, EE, ES, FI, FR, GB, GR, HR, IE, IT, LT, LV, NO, PT, RO, SE, SI, SK, TR	
II2H3P	20, 50 mbar	AT	
II2HM3B/P	20, 30 mbar	IT	
II2HM3P	20, 37 mbar	IT	
II2HS3B/P	25, 30 mbar	HU	
II2L3B/P	25, 30 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
LUNA STYLE 1.12; LUNA PLATINUM 1.12	nominal heat output: 2,0...12,0 kW heat input (Hi): 2,1...12,4 (drinking water: ...12,4) kW	
LUNA STYLE 1.24; LUNA PLATINUM 1.24	nominal heat output: 2,4...24,0 kW heat input (Hi): 2,5...24,7 (drinking water: ...24,7) kW	
LUNA STYLE 1.35; LUNA PLATINUM 1.35	nominal heat output: 3,4...32,0 kW heat input (Hi): 3,5...33,0 (drinking water: ...34,9) kW	
LUNA STYLE 24; LUNA PLATINUM 24	nominal heat output: 2,4...20,0 kW heat input (Hi): 2,5...20,6 (drinking water: ...24,7) kW	
LUNA STYLE 30	nominal heat output: 3,0...24,0 kW heat input (Hi): 3,1...24,7 (drinking water: ...31,0) kW	
LUNA STYLE 35; LUNA PLATINUM 35	nominal heat output: 3,4...28,0 kW heat input (Hi): 3,5...28,9 (drinking water: ...34,9) kW	

### Hints of Utilization /Remarks

#### Verwendungshinweise / Bemerkungen

Additionally tested appliance categories, supply pressures and countries of destination:

AL, BG, ES, MK, PT: II2H3B/P (20, 30 mbar)

AL, BG, MK: II2H3P (20, 37 mbar)

DE: II2N3B/P (20, 50 mbar)

FR: II2Er3B/P (20/25, 37 mbar)

MK: I3B/P (30 mbar)

flue types B23, B23P, B33, C13(x), C33(x), C43(x), C43P, C53(x), C63(x), C83(x), C93(x), C(10)3(x), C(11)3(x): according to installation manual with flue systems of SIT (approval no. 0476-CPR-8045) and Groppalli (approval no. 2592-CPR-0001) In the non-EU countries the conformity approval will be accepted if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.

The recognition of the CE mark in the United Kingdom is currently limited to Januar 1st, 2023.

The boilers are qualified for the addition of up to 20 vol.-% hydrogen to natural gas (G20) as burning gas according to DVGW CERT ZP 3100.

DVGW