

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CQ0330
Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräterichtlinie (2009/142/EG)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Saunier Duval ECCI 17 Avenue de la Petite Baratte, F-44315 Nantes Cedex 03
Distributor <i>Vertreiber</i>	Saunier Duval ECCI 17 Avenue de la Petite Baratte, F-44315 Nantes Cedex 03
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
Product Description <i>Produktbezeichnung</i>	Condensing water heater, optional with supply for drinking water storage
Model <i>Modell</i>	...KKS
Countries of Destination <i>Bestimmungsländer</i>	CZ, HU, LT, PL, RU, SK, UA
Test Reports <i>Prüfberichte</i>	type testing: 159495cT0/17302 from 09.09.2015 (GWI)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 15502-1 (01.10.2012) DIN EN 15502-2/1 (01.01.2013)

File Number
Aktenzeichen 15-0242-GEE

16.10.2015 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz, IP20
Elektrische Daten

Appliance Categories <i>Gerätekategorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2ELw	20 mbar	PL	
I2H	20 mbar	CZ, LT, SK	
I2HS	25 mbar	HU	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
18KKS	nominal heat output: 5,0...17,2 kW heat input (Hi): 5,4...18,0 kW	
25KKS	nominal heat output: 7,2...24,3 kW heat input (Hi): 7,5...25,0 kW	
35KKS	nominal heat output: 10,1...33,3 kW heat input (Hi): 10,5...35,0 kW	
48KKS	nominal heat output: 13,9...47,2 kW heat input (Hi): 14,4...48,0 kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

flue types: B23, B33, B53, B53P, C13, C33, C43, C53, C83 und C93 according to installation manual No. 0020217244

Additionally tested appliance categories, supply pressures and countries of destination:

RU, UA: I2H (13 und 20 mbar)

In the Russian Federation and in the Ukraine the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Russian Federation and the Ukraine.

DVGW